

Acton Water District - PWS 2002000

Summary of Treated Water Per- and Polyfluoroalkyl Substances (PFAS) 2025

Sample Date	Sample Location			
	Clapp/Whitcomb WTP	Central Acton WTP	North Acton WTP	South Acton WTP
January 23, 2025	Not Sampled	11.8	Not Sampled	15
January 27, 2025	Not Sampled	Not Sampled	ND	Not Sampled
February 26, 2025	Not Sampled	Not Sampled	ND	14.3
March 10, 2025	Not Sampled	10	ND	15.5
April 28, 2025	Not Sampled	11.7	ND	17.4
May 7, 2025	Not Sampled	13.3	ND	12.2
June 16, 2025	Not Sampled	10.3	ND	17.8
July 21, 2025	Not Sampled	14.5	ND	18.6

Notes:

WTP = Water Treatment Plant

Units are in parts per trillion (ppt) or ng/L

ND = below method detection limit

Not Sampled = PFAS samples are not collected at each WTP on the same date or when a WTP is not producing water for consumption

Results provided are the sum of 6 PFAS Compounds - PFOA, PFOS, PFNA, PFHxS, PFHpA, and PFDA

Exceeds Massachusetts Department of Environmental Protection (MassDEP) Maximum Contaminant Level (MCL) of 20 ppt or ng/L

All treated water data is shared with consumers to be transparent. Not all of the data presented here will meet MassDEP data acceptance standards.